



 **1 LIFE SAFETY PLAN**  
SCALE: 1/4" = 1'-0"

EMERGENCY LIGHTING FACILITIES SHALL BE ARRANGED TO PROVIDE AN INITIAL ILLUMINATION THAT IS AT LEAST AN AVERAGE OF 1 FOOT CANDLE MEASURED ALONG THE PATH OF EGRESS AT FLOOR LEVEL.

EXIT WIDTH: MINIMUM CORRIDOR WIDTH TO BE 36" CLEAR

NOTE ①:  
PROPOSED KNOX BOX LOCATION AT 48" A.F.F. PROVIDE A KNOX COMPANY BRAND LOCKING KEY BOX WITH THE CITY OF GREENSBORO KEYWAY, MOUNTED ON THE EXTERIOR, NEAR THE MAIN ENTRANCE, NO HIGHER THAN 60" A.F.F. INSTALL PER 2018 IFC SECTION 506.1. CONFIRM ALL REQUIREMENTS WITH FIRE MARSHALL PRIOR TO INSTALLATION.

NOTE ②:  
INSTALL VISIBLE SIGN STATING: "THIS DOOR TO REMAIN UNLOCKED WHEN SPACE IS OCCUPIED."  
SIGNAGE TO MEET LOCAL JURISDICTION REQUIREMENTS.

NOTE ③:  
CLASS B FIRE EXTINGUISHER: LOCATION OF FIRE EXTINGUISHER TO BE APPROVED BY AUTHORITY HAVING JURISDICTION PRIOR TO INSTALLATION



**JOHN FRANZ**  
architect

4055 International Plaza Suite 100  
Fort Worth, Texas 76109  
(817) 737-9922

**STRICKLAND BROTHERS**  
3223 BATTLEGROUND AVE.  
GREENSBORO, NC 27408

Revisions:

File Name:	21337_A0.5
Project No:	21337
Date:	12/17/21
Drawn By:	
Checked By:	TF

**A0.5**  
LIFE SAFETY PLAN