


CONTRACT DATE:	XXXXX
BUILDING TYPE:	XXXXX
PLAN VERSION:	XXXXX
SITE NUMBER:	315669
STORE NUMBER:	XXXXX

SPEARS CREEK CHURCH RD.  
ELGIN, SC 29045



## E2.2

TYPE: I-HEATING, C-COOLING, R-KITCHEN RESISTIVE, KM-KITCHEN MOTOR, WH-WATER HEATER, OM-OTHER MOTORS, O-OTHER	
DISCONNECT TYPE: HP-HP RATED SWITCH, CAP-CORD, LUG, L&P-Locking CORD & PLUG, F-FUSED, NF-NON-FUSED, MCCB-MOLDED CASE CIRCUIT BREAKER	
SUPPLIED/INSTALLED BY: E-ELECTRICAL, CONTRACTOR CH&WC CONTRACTOR, PC-PLUMBING CONTRACTOR, ES-EQUIPMENT SUPPLIER	
*VOLTAGE DROP CALCULATION FORMULAS COURTESY OF DOOPER BUSSMANN.	
NOTES:	
1- REQUIRES SHUNT TRIP PROTECTION	4- CORD, PLUG & RECEPTACLE SUPPLIED AND INSTALLED BY EC.
2- CORD & PLUG SUPPLIED AND INSTALLED BY ES. EC SHALL PROVIDE RECEPTACLE.	5- SINGLE PHASE, THREE WIRE EQUIPMENT. PROVIDE PHASE CONDUCTORS AND GROUND.
3- CORD & PLUG SUPPLIED AND INSTALLED BY ES. RECEPTACLE SUPPLIED BY ES AND INSTALLED BY EC.	6- THREE PHASE, FOUR WIRE EQUIPMENT. PROVIDE NEUTRAL CONDUCTOR AND GROUND.
	7- OUTLETS SUPPLIED AND INSTALLED BY ES. CONDUIT & WIRING PROVIDED BY EC.
	8- HARD WIRED CONNECTION BY E.C.