

**ALABAMA DEPARTMENT
OF ENVIRONMENTAL MANAGEMENT**

In The Matter Of:)

Armstrong Oil Company, Inc.)

Circle C #22)

UST Facility ID No. 10304-089-011952)

Huntsville, Madison County, Alabama)

CONSENT ORDER

No. 00-224-CGW

FINDINGS


Pursuant to the provisions of the Alabama Environmental Management Act, §§ 22-22A-1 through 22-22A-16, Code of Alabama (1975), as amended; the Alabama Underground Storage Tank and Wellhead Protection Act, §§ 22-36-1 through 22-36-10, Code of Alabama (1975), as amended; the ADEM Administrative Code of Regulations ("ADEM Admin. Code R.") Promulgated pursuant thereto, and without the adjudication of any issues of fact or law and upon the consent of the parties hereto, the Alabama Department of Environmental Management (hereinafter, "the Department") makes the following FINDINGS:

1. **Armstrong Oil Company, Inc.** (the "owner") is the registered owner of an underground storage tank facility located at Circle C #22, 4113 Bob Wallace Avenue, Huntsville, Madison County, Alabama 35805, designated as ADEM Facility I.D. Number 10304-089-011952.

2. The Alabama Department of Environmental Management is a duly constituted agency of the State of Alabama pursuant to §§ 22-22A-1 through 22-22A-16, Code of Alabama 1975, as amended.

3. Pursuant to § 22-22A-4(n), Code of Alabama 1975, as amended, the Alabama Department of Environmental Management is the State Environmental Control Agency for the purposes of Federal Environmental Law, including 42 U.S.C. §6991, et.seq., as amended.

4. The Alabama Department of Environmental Management is authorized to administer and enforce the provisions of the Alabama Underground Storage Tank and Wellhead Protection Act, §§ 22-36-1 through 22-36-10, Code of Alabama 1975, as amended.



5. During an inspection of the UST facility on December 27, 1999, Department personnel documented the violations alleged herein.

6. Pursuant to ADEM Admin. Code R. 335-6-15-.14, owners of new and existing UST systems must provide a method or combination of methods of release detection.

7. The owner has failed to provide a method of release detection, in violation of ADEM Admin. Code R. 335-6-15-.14.

8. The owner neither admits nor denies the Findings contained in this consent order. However, in an effort to cooperate with the Department and to resolve the allegations cited above, the owner consents to the terms of this Order

9. The Department agrees to this Consent Order upon a determination that the terms are in the best interests of the citizens of Alabama in resolving the alleged violations cited hereinabove.

ORDER

Based upon the foregoing FINDINGS and pursuant to §§22-22A-5(10), 22-22A-5(18), and 22-36-3, Code of Alabama (1975), as amended, and with the consent of the Armstrong Oil Company, Inc. it is hereby ORDERED:

A. That there is hereby assessed a civil penalty against Armstrong Oil Company, Inc. in the amount of Two Thousand Dollars (\$2,000.00) to be paid to the Alabama Department of Environmental Management within thirty (30) days of issuance of this Order.

B. If the violations cited above are corrected on or before the issuance date of this Order, Armstrong Oil Company, Inc. shall execute and file with the Department the attached "Certification of Compliance" indicating the upgrade(s) performed on the UST system and the dates such upgrade(s) were completed. The "Certification of Compliance" will be subject to verification, and the Department may proceed with additional enforcement actions and enhanced penalties if the cited violations have not been corrected.

C. If the violations cited above have not been corrected as of the issuance date of this Order, Armstrong Oil Company, Inc. shall immediately discontinue use of the substandard UST system in accordance with ADEM Admin. Code R. 335-6-15-.36 ("Temporary Closure"),

provide notification of temporary closure to the Department, and remain temporarily closed until such time as the violations are corrected pursuant to sub-paragraph (1) below or the UST system is permanently closed:

(1) If the violations cited herein are corrected, Armstrong Oil Company, Inc. may reactivate the system upon executing and filing with the Department the attached "Certification of Compliance." The "Certification of Compliance" will be subject to verification, and the Department may proceed with additional enforcement actions and enhanced penalties if the cited violations have not been corrected

D. That Armstrong Oil Company, Inc. otherwise shall comply with all applicable requirements for each UST and shall continuously remain in compliance therewith each and every day thereafter until such time the UST is permanently removed from service pursuant to ADEM Admin. Code R. 335-6-37.

E. That this Consent Order shall apply to and be binding upon both parties, their directors, officers, and all persons or entities acting under or for them. Each signatory to this Consent Order certifies that he or she is fully authorized by the party he or she represents to enter into the terms and conditions of this Consent Order, to execute the Consent Order on behalf of the party represented and to legally bind such party.

F. That subject to the terms of these presents and subject to provisions otherwise provided by statute, this Consent Order is intended to operate as a full resolution of the alleged violations cited in this Order.


G. That Armstrong Oil Company, Inc. is not relieved from any liability upon the failure to comply with any provision of the Consent Order.

H. That for purposes of this Order only, Armstrong Oil Company, Inc. agrees that the Department may properly bring an action to compel compliance with the terms and conditions contained herein in a court of competent jurisdiction, including, but not limited to, Montgomery County Circuit Court. Armstrong Oil Company, Inc. also agrees that in any action brought by the Department to compel compliance with the terms of this Agreement, Armstrong Oil Company, Inc. shall be limited to the defenses of Force Majeure, compliance with this Agreement and physical impossibility.

I. That this Order does not preclude the Department from taking other enforcement actions based on these facts regarding violations of other regulatory programs. Should additional facts and circumstances be discovered in the future concerning Armstrong Oil Company, Inc. which would constitute possible violations not addressed in this Order, or if the violations noted herein continue, then such future violations shall be addressed in Orders or litigation initiated by the Department, or such other enforcement action as may be appropriated, and Armstrong Oil Company, Inc. shall not object to such future orders, litigation or enforcement action based on the issuance of this Consent Order.

J. That by agreement of the parties, this Order shall be considered final and effective immediately upon signature of all parties. This Consent Order shall not be appealable, and Armstrong Oil Company, Inc. does hereby waive any hearing on the terms and conditions of same.

ORDERED and ISSUED this 27th day of September, 2000.




(Signature)

David W. Casimano Chief Operating Officer

(Please Print Name and Title of Authorized Officer)

Armstrong Oil Company, Inc.

Date Signed: 9/27/00



James W. Warr, Director

Alabama Department of
Environmental Management

ALABAMA DEPARTMENT
OF ENVIRONMENTAL MANAGEMENT

In The Matter Of:

Armstrong Oil Company, Inc.
Circle C #22
UST Facility ID No. 10304-089-011952
Huntsville, Madison County, Alabama

CONSENT ORDER

No. _____

CERTIFICATION OF COMPLIANCE

I certify under penalty of law that the UST violations cited in this Consent Order have been corrected and the upgrades identified below were completed on the dates indicated (check all that apply):

☐

Release Detection.

UST systems have been upgraded with an approved method of release detection in accordance with ADEM Administrative Code R. 335-6-15-.14.

Date Completed: 12/31/99

☐

Spill Prevention.

UST systems have been upgraded with an approved method of spill prevention in accordance with ADEM Administrative Code R. 335-6-15-.07.

Date Completed: 9/15/98

☐

Overfill Prevention.

UST systems have been upgraded with an approved method of overfill prevention in accordance with ADEM Administrative Code R. 335-6-15-.07.

Date Completed: 9/15/98

☐

Corrosion Protection.

UST piping has been upgraded with an approved method of corrosion protection in accordance with ADEM Administrative Code R. 335-6-15-.07.

Date Completed: 9/15/98

DATED this 21 day of September, 2000.

(Signature)

David W. Lusimano, Chief Operating Officer

Armstrong Oil Company, Inc.